

Beam Timing and Cavity Phasing

Rosalyn Koscica


Cornell Laboratory for Accelerator Sciences and Education (CLASSE)

ERL 2019



ERL: Energy Recovery Linac


- Linac-quality beams
- Higher beam power
- Deceleration recovers energy





ERL: Energy Recovery Linac


- Linac-quality beams
- Higher beam power
- Deceleration recovers energy





Cornell-Brookhaven ERL Test Accelerator (CBETA)

- Beam passes 8 times through a 6-cavity linac
- 4 accelerations, 4 decelerations
- Nonultrarelativistic beam





- CBETA 1-turn tests
- Multi-turn optimization*
- ERL symmetry: how can it help?*
- Symmetric CBETA model optimization*
- Longitudinal beam symmetry*

*Recently published, *Editor's Suggestion*:

Phys. Rev. Accel. Beams **22**, 091602

DOI: <https://doi.org/10.1103/PhysRevAccelBeams.22.091602>



ERL Requirements

- Reduce power load on cavities (0 W)



Linac: 6 cavities



Return loop: 4 independent paths



ERL Requirements

- Reduce power load on cavities (0 W)
- Achieve the correct max energy (150 MeV)



Linac: 6 cavities




Return loop: 4 independent paths



ERL Requirements

- Reduce power load on cavities (0 W)
- Achieve the correct max energy (150 MeV)
- Get equal beam energy in corresponding loops (e.g. first/last)



Linac: 6 cavities



Return loop: 4 independent paths



Multi-turn Challenges

If beam is assumed to always be ultra-relativistic ($v=c$) in CBETA...



Linac: 6 cavities




Return loop: 4 independent paths



Multi-turn Challenges

If beam is assumed to always be ultra-relativistic ($v=c$) in CBETA...

- Each cavity uses up to **46 kW** per 40 mA beam



Linac: 6 cavities



Return loop: 4 independent paths



Multi-turn Challenges

If beam is assumed to always be ultra-relativistic ($v=c$) in CBETA...

- Each cavity uses up to **46 kW** per 40 mA beam
- Beam ends with **double** the injection energy (6 MeV $\rightarrow$ **12 MeV**)



Linac: 6 cavities




Return loop: 4 independent paths



CBETA Energy Recovery

1-turn CBETA operation

- $6 \rightarrow 42 \rightarrow 6$ MeV
- Cavity phases near on-crest
- Above 99.8% energy recovery in each cavity





CBETA 4-Turn Optimization

Objectives

- Power load: 6
- Max beam energy: 1
- Loop energies: 6

Total: 13



CBETA 4-Turn Optimization

Objectives

- Power load: 6
- Max beam energy: 1
- Loop energies: 6

Total: 13

Degrees of Freedom

- Cavity phase: 6
- Cavity voltage: 6
- Loop lengths (times): 4

Total: 16 (need ≥ 13)



CBETA 4-Turn Optimization

Objectives

- Power load: 6
- Max beam energy: 1
- Loop energies: 6

Total: 13

Degrees of Freedom

- Cavity phase: 6
- Cavity voltage: 6
- Loop lengths (times): 4


Total: 16 (need ≥ 13)

Solving requires a **13-by-13** system, at minimum.

Reduce by imposing **ERL symmetry**.




What is ERL symmetry?





What is ERL symmetry?





Outcomes of Symmetry


- Correlate phases of cavity pairs
- Set length of central (4th) loop
- Each cavity *pair* has full energy recovery



Outcomes of Symmetry

- Correlate phases of cavity pairs
- Set length of central (4th) loop
- Each cavity *pair* has full energy recovery

Symmetric energy,
arbitrary phases 1-3







Outcomes of Symmetry

- Correlate phases of cavity pairs
- Set length of central (4th) loop
- Each cavity *pair* has full energy recovery

Symmetric energy,
arbitrary phases 1-3



Symmetric energy,
optimized phases 1-3





Optimization: why symmetry?

Objective	# Targets, normal ERL	# Targets, symmetric
Load per cavity Load = 0	6	3
Max beam energy $E - (150 \text{ MeV}) = 0$	1	1
Acc/dec loop beam energy	6	0
Total	13	4



Optimization: why symmetry?

- Degrees of Freedom
 - Phase (paired): 3
 - Voltage (paired): 3
 - Loop lengths: 4
- **Total: 10 (need ≥ 4)**

Objective	# Targets, normal ERL	# Targets, symmetric
Load per cavity Load = 0	6	3
Max beam energy $E - (150 \text{ MeV}) = 0$	1	1
Acc/dec loop beam energy	6	0
Total	13	4




Optimization: why symmetry?

- Degrees of Freedom
 - Phase (paired): 3
 - Voltage (paired): 3
 - Loop lengths: 4
- **Total: 10 (need ≥ 4)**
- Opt. system shrinks
 - Old: 13-by-13
 - New: 4-by-4

Objective	# Targets, normal ERL	# Targets, symmetric
Load per cavity Load = 0	6	3
Max beam energy $E - (150 \text{ MeV}) = 0$	1	1
Acc/dec loop beam energy	6	0
Total	13	4



Creating Symmetry: 2 cavities



Cavity A accelerates, D decelerates


- D's electric field mirrors that of A
- Zero total load of system

Cavity phase

- $\phi_{in,D} = \phi_{out,A} + \omega\Delta t_{loop} = -\phi_{out,A}$ (Odd-cell cavities, e.g. CBETA)
- $\phi_{in,D} = \phi_{out,A} + \omega\Delta t_{loop} = \pi - \phi_{out,A}$ (Even-cell cavities)



Creating Symmetry: 2 cavities



Cavity A accelerates, D decelerates


- D's electric field mirrors that of A
- Zero total load of system

Cavity phase

- $\phi_{in,D} = \phi_{out,A} + \omega \Delta t_{loop} = -\phi_{out,A}$
- $\phi_{in,D} = \phi_{out,A} + \omega \Delta t_{loop} = \pi - \phi_{out,A}$


(Odd-cell cavities, e.g. CBETA)

(Even-cell cavities)





Multi-turn Symmetry



Electric fields must be mirrored in acceleration/deceleration.

- Let $\phi_{in,mn} = \phi_{0,n} + \omega t_{in,mn}$

Symmetric cavity pair: $\phi_{in,Dec} = -\phi_{out,Acc}$


$$\phi_{0,n} + \omega t_{in,mn} = -(\phi_{0,n'} + \omega t_{out,m'n'})$$

$$\phi_{0,n} = -\phi_{0,n'} - \omega t_{total}$$

$$t_{loop,M/2} = t_{total} - 2t_{acceleration}$$



Multi-turn Symmetry



Electric fields must be mirrored in acceleration/deceleration.

- Let $\phi_{in,mn} = \phi_{0,n} + \omega t_{in,mn}$

Symmetric cavity pair: $\phi_{in,Dec} = -\phi_{out,Acc}$

$$\phi_{0,n} + \omega t_{in,mn} = -(\phi_{0,n'} + \omega t_{out,m'n'})$$

$$\phi_{0,n} = -\phi_{0,n'} - \omega t_{\text{total}}$$

$$t_{\text{loop},M/2} = t_{\text{total}} - 2t_{\text{acceleration}}$$



CBETA Cavity Models


- Model cavities as pillboxes using *Mathematica* or *Bmad*.



CBETA Cavity Models

- Model cavities as pillboxes using *Mathematica* or *Bmad*.

Runge Kutta *Bmad* cavities (RK)







CBETA Cavity Models

- Model cavities as pillboxes using *Mathematica* or *Bmad*.

Thin Lens cavities (TL)



Runge Kutta *Bmad* cavities (RK)







CBETA Cavity Models

- Model cavities as pillboxes using *Mathematica* or *Bmad*.


Thin Lens cavities (TL)



Ultra-relativistic cavities (UR)



Runge Kutta *Bmad* cavities (RK)







CBETA Cavity Models

- Model cavities as pillboxes using *Mathematica* or *Bmad*.


Thin Lens cavities (TL)




Ultra-relativistic cavities (UR)



Finite Time-tracked cavities (FT)



Runge Kutta *Bmad* cavities (RK)







CBETA Cavity Models

- Model cavities as pillboxes using *Mathematica* or *Bmad*.


Thin Lens cavities (TL)




Ultra-relativistic cavities (UR)



Finite Time-tracked cavities (FT)



Runge Kutta *Bmad* cavities (RK)



Mathematica (TL, UR, FT models) are solved with Newton's method.
Bmad (RK model) uses Levenberg-Marquardt optimization.




Optimized Models

ERL output	Objective (min)	Objective (max: RK)	Design target
Cavity load	28 pW (TL)	32 μ W	0 W
Max energy (offset)	37 μ eV (TL)	0.9 eV	0 eV
Loop 1 (MeV)	42.00 (UR)	42.18	42.00
Loop 2	78.01 (UR)	78.20	78.00
Loop 3	114.00 (UR)	114.23	114.00

Avg. solution deviation
from targets

ΔE (μ eV)





Solutions: Error Tolerance

Find necessary control
precision of optimized
settings.

- All inputs modeled with
“expected” fluctuations

Objective goals

- Load: 2 kW
- Max energy: ± 150 keV

ERL inputs	Tolerance (max: FT)	Tolerance (min: UR)	Expected resolution
Phase	67.0 %	51.0 %	0.100°
Voltage	67.0 %	50.7 %	600 V
Loop length	67.0 %	50.8 %	0.333 mm



Longitudinal beam symmetry

- Symmetry achieved with 1 particle
 - What about >1000 particles in a beam?



Longitudinal beam symmetry

- Symmetry achieved with 1 particle
 - What about >1000 particles in a beam?
- Goals
 - Similar energy spread at injection and beam stop
 - Minimize energy spread at beam stop




Longitudinal beam symmetry

- Symmetry achieved with 1 particle
 - What about >1000 particles in a beam?
- Goals
 - Similar energy spread at injection and beam stop
 - Minimize energy spread at beam stop
- How?
 - “Tilt” initial beam using off-crest injector phases



Beam Tilting Results


Normal input,
Model output






Beam Tilting Results

Normal input,
Model output




Tilted input,
Equal output spread






Beam Tilting Results


Normal input,
Model output



Tilted input,
Equal output spread



Tilted input,
Minimized output spread





- Ultra-relativistic ERL would require up to **46 kW** power per cavity
 - Only 2 kW available
 - Reduce load by optimizing cavity phase, voltage, and loop time



- Ultra-relativistic ERL would require up to **46 kW** power per cavity
 - Only 2 kW available
 - Reduce load by optimizing cavity phase, voltage, and loop time
- Optimization requires solving a **large system**
 - 13 variables/constraints



- Ultra-relativistic ERL would require up to **46 kW** power per cavity
 - Only 2 kW available
 - Reduce load by optimizing cavity phase, voltage, and loop time
- Optimization requires solving a **large system**
 - 13 variables/constraints
- Symmetry **reduces system size**
 - 4 variables/constraints



- Ultra-relativistic ERL would require up to **46 kW** power per cavity
 - Only 2 kW available
 - Reduce load by optimizing cavity phase, voltage, and loop time
- Optimization requires solving a **large system**
 - 13 variables/constraints
- Symmetry **reduces system size**
 - 4 variables/constraints
- Symmetric system is successfully solved
 - Numeric solutions match targets with **10^{-7}** accuracy
 - Realistic solution tolerances are reasonable for CBETA



- Ultra-relativistic ERL would require up to **46 kW** power per cavity
 - Only 2 kW available
 - Reduce load by optimizing cavity phase, voltage, and loop time
- Optimization requires solving a **large system**
 - 13 variables/constraints
- Symmetry **reduces system size**
 - 4 variables/constraints
- Symmetric system is successfully solved
 - Numeric solutions match targets with **10^{-7}** accuracy
 - Realistic solution tolerances are reasonable for CBETA
- Longitudinal beam tilting can **increase symmetry** in energy spread


Acknowledgements

CLASSE & Cornell University

- Dr. Georg Hoffstaetter
- Dr. David Sagan
- Dr. Christopher Meyes
- William Lou
- Nilanjan Banerjee
- Gayathrini Premawardhana

Funding:

- Brookhaven National Laboratory
- New York State Energy Research & Development Authority (NYSERDA)



CLASSE

Cornell Laboratory for Accelerator-based Sciences & Education



NYSERDA
Sponsored