

Radiological safety aspects of the design of the RNB facilities

*D. Ene, D. Ridikas, B. Rapp, J.C David, D. Doré
CEA-Saclay, IRFU/SPHN, F-91191 Gif-sur-Yvette, France*

for EURISOL Task#5 Safety & Radioprotection:

GANIL, France, FZJ, Germany, LMU, Germany, CERN, EU
CEA, France, NIPNE, Romania, FI, Lithuania, Univ. Warsaw, Poland

Radiation safety issues

⇒ the strategy used for the design of RNB facilities

EURISOL-DS project (illustration) –early stage

Problems addressed:

- ✓ **Legislation framework** sets-up safety requirements protection of the environment, public and staff
- ✓ **Radioactive sources identification and estimation** deciding the radiation safety features
- ✓ **Safety design objectives:**
(*Protection of workers, public & environment*)

Goal & Strategy

1. Operation phase :

- ❑ **Protection against radiations** => optimum shielding configuration
- ❑ **Containment of radioactive materials** => **risk analysis** > equipments are adequate to minimize risk of radioactive material dispersion.
- ❑ **Compatibility with the environment** => **impact of the radioactive releases**

Radiological studies: Characterization of the prompt radiation field for normal and accident conditions

Safety studies: Classification of the events & Risk assessment

Environmental studies: Characterization of the specific site & impact assessment


2. Post -operational phase:

- ❑ **Protection against radiations** => **measures to limit the exposure & working procedures**
during maintenance and interventions
machine will be **dismantled and decommissioned**
waste transportation/disposal
- ❑ **Compatibility with the environment** => **impact of the radioactive releases**
>decommissioning & waste transportation/disposal

Radiological studies: assessment of the residual radiation field => specifications on the exposure of the personnel



Environmental studies: Characterization of the specific site & impact assessment

EURISOL conceptual lay-out





Two ways to produce RIBs:

- Direct:
high energy spallation
100 kW



Direct target: $R=1.8\text{cm}, L=40\text{cm}$

- Converter:
neutron fission
4MW



Fission target(30kW)

($R_{\text{ext}}=1.75\text{cm}, R_{\text{int}}=0.4\text{cm}, H=20\text{cm}$)⁴

Legislation framework:

☐ JUSTIFICATION

☐ LIMITATION

☐ OPTIMISATION

Design limits for occupied areas/ ICRP 60

	H*(10) [$\mu\text{Sv h}^{-1}$]	Total_H*(10) [mSv y ⁻¹]
Public areas:	0.1	1
inside fence	1	
Controlled areas	10	20 / 2000 h
Full beam loss:	Total_H*(10) $\leq$ 50 μSv	

CERN guidelines:

H*(10) [mSv h ⁻¹]	Maintenance constraints
>0.1	Planification and optimisation of all work
>2	+ limited intervention time & remote handling
>20	Remote handling essential

Radioactive sources identification & estimation

Design guidelines & previous experience => Basic estimates

Few exemples:

Equipement	primary	Energy	Intensity (pps)	Losses (pps)	Specific sources
Linac	p	1GeV	$(1-4)*6*10^{15}$	$6*10^{12}/E[\text{MeV}] \text{ m}^{-1}$	-Few hot spots -Neutron backscatter
Linac#1 (L=209m)	^{132}Sn	$(0.6 - 150) \text{ MeVu}^{-1}$	$6*10^{12}$	$(6*10^7 - 6*10^8) \text{ m}^{-1}$	No spots specification
Linac#2 (L=156m)	^{132}Sn	$(0.6 - 150) \text{ MeVu}^{-1}$	$6*10^{12} - 2.5*10^{12}$	$(6*10^7 - 6*10^8) \text{ m}^{-1}$ $\sim 4*10^{12}$ (stripper zone)	No spots specification

Radioactive sources estimation

- Prompt radiation

PHITS, FLUKA, MCNPX-HI


Mixed Φ & Conversion factors $\rightarrow H^*(10)$

Benchmarks related to prompt radiation

$p(1.6 \text{ GeV}) + \text{Fe} \rightarrow \text{neutrons}$


(MCNPX)

$\text{Fe}(p, xn)X$ à $E_p = 1600 \text{ MeV}$




$\text{Ar}(95 \text{ MeV/u}) + \text{Cu} \rightarrow \text{neutrons}$

PHITS



Neutron penetration in concrete shield
MCNPX




Radioactive sources estimation

• Residual radiation:


Benchmarks related to induced activity

Geometry and materials description




PHITS/
MCNPX

Neutron flux in i^{th} cell



Residues in i^{th} cell



DCHAIN-
SP-2001/
CINDER

Irradiation
Scheme

5000h irradiation at 4MW
40 years & duty factor 0.7



Activation products
&
Photon sources

MCNPX

$H^*(10)$


HIAT'09, 8-12.06.2009-Venezia

Production of Residual Nuclei



Estimation of radiation levels: MMW target assembly


Hg converter and secondary fission targets



First version of design =>

BULK SHIELDING

Biasing methods



MAFF-like configuration =>


NEUTRON STREAMING

**Monte Carlo & generic studies ->
choices of materials & shielding effect**

Estimation of radiation levels: MMW target assembly

• Prompt radiation: BULK SHIELDING

FLUKA (CERN)




+

$$H(\theta, d, R) = H_0(\theta) \exp\{-\sum_i d_i / \lambda_i(\theta)\} / R^2$$

Attenuation formula

Shielding starts 20cm away from the target


Shielding materials
2m iron
+
2m concrete
shielding






- 1 m of iron
- For $\theta = 0, 90, 180^{\circ}$
→ 9.0, 8.0 & 6 m of concrete

Estimation of radiation levels: MMW target assembly

• Prompt radiation: NEUTRON STREAMING FLUKA (CERN)




Fission target handling room






Estimation of radiation levels: Postaccelerator

**Method
(CEA)**



PHITS




A shield designed for a continuous beam loss of $10^{-4} m^{-1}$ (point loss of $6.25 \cdot 10^9 \text{ ion s}^{-1}$) during the routine operation is also **adequate** for an accident loss of the full beam at a localised point, providing that **the linac cutoff time is less than**

1s.

Estimation of radiation levels: Postaccelerator


neutrons




$$H^*(E_p, d / \lambda) = \frac{H_1(E_p)}{r^2} \exp\left[-\frac{d}{\lambda_1}\right] + \frac{H_2(E_p)}{r^2} \exp\left[-\frac{d}{\lambda_2}\right] \quad !!$$

* Agosteo S, Nakamura T, et al. NIM/B 217, 2004

E [MeV/u]	H ₁ [Sv m ² ion ⁻¹]	λ ₁ [g cm ⁻²]	H ₂ [Sv m ² ion ⁻¹]	λ ₂ [g cm ⁻²]
150	2.00E-10	38.78	7.98E-11	62.00
115	1.13E-10	23.50	6.14E-11	57.32
76	6.18E-11	21.36	1.27E-11	53.20
45.5	1.69E-11	12.19	1.55E-11	40.52
21.3	-	-	2.00E-12	33.57



21 MeV/u 150 MeV/u




Estimation of radiation levels: Postaccelerator


Other species & secondaries

Beam direction
→


Beam on stopping Cu target
Ronningen & Remec, 2005




proton : 1 GeV



He-3 : 777 MeV/u



U-238 : 400 MeV/u



Photon $H^*(10) < 3\%$ Total $H^*(10)$

3 m of concrete:


!!

Neutron $H^*(10)$ for ^{6}He (250MeV/u) ~ 5
Neutron $H^*(10)$ for ^{132}Sn (150MeV/u)


**Safety operation domain:
energy range and
beam intensities.**

OPERATION: shielding configuration

Conceptual design of 100kW target station (CERN)




- Underground target position
- Front-end retracts vertically
- Hot-cell for target exchange
- Separator in 3rd level
- Neighboring hot-cell accessible during run




OPERATION: shielding configuration

Shielding of Postaccelerator (CEA)




Staff	Energy [MeV]	21.3	45.5	76	115	150
	Length [m]	44	40	40	40	45
	Thickness (cm)	70	130	175	210	225
	$V_{staff} \text{ (m}^3\text{)}$	338.05* $\rightarrow$ 4732.7 for a tunnel surface of 3 m x 4 m				
Public	Thickness (cm)	140	195	245	320	380
	$V_{public} \text{ (m}^3\text{)}$	536.6* $\rightarrow$ 7512.4 for a tunnel surface of 3 m x 4 m				



	Energy [MeV]	21.3	Stripper	45.5	76	115	150
	Length (m)	44	10	31	21	33	17
Staff	Thickness (cm)	70	160	110	150	180	200
	$V_{staff} \text{ (m}^3\text{)}$	205.8* $\rightarrow$ 2881.2 for a tunnel surface of 3 m x 4 m					
Public	Thickness (cm)	140	235	185	230	295	325
	$V_{public} \text{ (m}^3\text{)}$	343.4* $\rightarrow$ 4120.2 for a tunnel surface of 3 m x 4 m					

OPERATION: shielding configuration



Beam Dump cavity: thickness of lateral wall (CEA)



¹³²Sn²⁵⁺

Beam power = 19.8 kW (150 MeV/u)

Beam size $\sigma = 2$ mm



material	H ₁ [Sv m ²]	λ ₁ [g cm ⁻²]	H ₂ [Sv m ²]	λ ₂ [g cm ⁻²]	SHIELD [cm]	
					Staff	Public
concrete	1.747E+03	23.7	1.338E+02	60.36	364	480
steel	-	-	5.000E+04	112.14	254	320


OPERATION: containment of volatile radioactivity

Dispersion of radioactivity: from MAFF

P. Thirolf et al.
(LMU)

EURISOL $\rightarrow$ 10 higher!

Dose in distance of 1m after 1 day decay time:



Capability of Cryotrap

3 cryotraps prototypes tested:

Retention capability (vs. pressure behind cryotrap)

'carry over': fraction of leaking gas load transported across cryotrap



large



small




Cryotrap works within (simulated) expectations $\rightarrow$ 99.98% of volatile radioactivity can be localized!

OPERATION:Containment | Risk register

derived from the CERN-AB risk register elaborated by P. Bonnal (05/05/2003)

•The methodology used



•The file format

1	Insignificant	< 1 day of loss of physics, or < 0.5% of EURISOL annual budget, or No environmental consequence
2	Moderate	1 day < < 1 week of loss of physics, or Management level, or 0.5 < < 4% of EURISOL annual budget, or Injury, no loss of working day
3	Major	3 < < 5 weeks of loss of physics, or Executive board level, or Additional budget, or Injury, loss of working day
5	Catastrophic	~1 year of loss of physics, or EURISOL future jeopardized, or Loss of life

EURISOL-DS RISK REGISTER

Equipment			Operational phase and Risk			RP [mSv/h] and intervention		Risk assessment before mitigation			Mitigation of Risk	Risk assessment after mitigation		
Owner	Name and location	Acronym - Number	Action type	description of failure	Description of associated risk	Dose rate	Job duration	Probability	Impact	Score	Comments - Needed actions	Probability	Impact	Score

- 1 **Rare**, i.e. less than once in 25 years ; probability less than 0.1
- 2 **Possible**, i.e. one time in 5 to 10 years ; probability between 0.2 and 0.5
- 3 **Likely**, i.e. one time in 2 to 5 years ; probability 0.6
- 4 **Frequent**, i.e. about once a year ; probability 0.9

Risk score calculated as follow: $RS = P \times I$ (updated via cell A1 click)
 $RS \in [1,2]$ **low**; $RS \in [3,8]$ **medium**; $RS \in [9,20]$ **high**

OPERATION:Containment | Risk register

Main risks for the Hg converter

EURISOL-DS RISK REGISTER


Equipment			Operational phase and Risk			RP [mSv/h] and intervention		Risk assessment before mitigation			Mitigation of Risk	Risk assessment after mitigation		
Owner	Name and location	Acronym - Number	Action type	description of failure	Description of associated risk	Dose rate	Job duration	Probability	Impact	Score	Comments - Needed actions	Probability	Impact	Score
T2	CGS target vessel	???	Operation	Rupture of the vanes	Loss of Hg flow, flow blockage and cavitation			2	2	4	Instrumentation to control Hg flowrates	2	1	2
					Explosion by Hg boiling			1	5	5	Containement of Hg (safety hull)	1	1	1
					Overheating of the window			3	3	9	Instrumentation to control Window temperature	3	1	3
					Partial melting of the window			1	5	5	Containement of Hg (safety hull)	1	1	1

Main risks for the Fission target

EURISOL-DS RISK REGISTER


Equipment			Operational phase and Risk			RP [mSv/h] and intervention		Risk assessment before mitigation			Mitigation of Risk	Risk assessment after mitigation		
Owner	Name and location	Acronym - Number	Action type	description of failure	Description of associated risk	Dose rate	Job duration	Probability	Impact	Score	Comments - Needed actions	Probability	Impact	Score
T4	UC target/running	RU-T-06	operation	firing target	stop of operation, target is lost, removal of target and replace with a new one, clean the pit region. The pit and beam line are highly contaminated.	1PBq	2000	2	5	10	avoid oxygen contamination, redundancy of safety valves. Neutral atmosphere during removal may be foreseen	1	5	5

POST-OPERATION: Activation of targets



Hg

MMW target



UCx

²³⁵U:


7% halogens

10% rare gases

1% actinides

Direct target | CEM2k
UCx(L=40cm,



R=1.8cm)




Hg		1 year after irradiation			10 years after irradiation		
		ISABEL-ABLA	CEM2k	INCL4-ABLA	ISABEL-ABLA	CEM2k	INCL4-ABLA
Total activity	Half life	9.810 ²	2.8 10 ³	4.1 10 ²	6.1 10 ²	1.6 10 ³	2.0 10 ²
¹⁹⁵ Au	186.1 d	2.8 10 ¹	2.410 ¹	2.6 10 ¹	2.1 10 ⁻⁴	1.8 10 ⁻⁴	2.0 10 ⁻⁴
¹⁴⁸Gd	74.6 y	2.110⁻¹	7.4 10⁻¹	1.1 10⁻¹	2.0 10⁻¹	6.8 10⁻¹	9.7 10⁻²
³ H	12.32 y	1.9 10 ²	2.3 10 ³	3.9 10 ¹	1.1 10 ²	1.4 10 ³	2.3 10 ¹
¹⁷² Hf	1.87 y	1.8 10 ²	2.3 10 ²	1.7 10 ²	6.5 10 ⁻¹	8.3 10 ⁻¹	6.1 10 ⁻¹
¹⁹⁴ Hg	444 y	3.0	1.2 10 ¹	2.6	3.0	1.2 10 ¹	2.5

HIAT'09, 8-12.06.2009-Venezia

Post-OPERATION: MMW target shielding



Stainless steel



Concrete

Activity map at 100days


40 years irradiation at 2.28 MW

1 MBq/g < A < 1 GBq/g


1 kBq/g < A < 1 MBq/g

1 Bq/g < A < 1 kBq/g


A < 1 Bq/g



Waste categories




Activities




Mases

POST-OPERATION: Postaccelerator tunnel




Activation of Cu structure (150 MeV/u)

Contribution of
the wall is
not significant



Activation of concrete (150 MeV/u)



Total activity due to implantation

Air activation using PHITS
(evaluated cross sections)


$^{14,15}\text{O}, ^{13}\text{N} \mid ^{41}\text{Ar} \ 0.35 \text{Bq cm}^{-3}$

Activity vs Discharge limit

Inhalation dose received by
workers intervening in tunnel

$10^{11} \text{ Bq } ^{132}\text{Sn}$ implantation



^{132}I accumulation after 1h



Air activation (150 MeV/u)

POST-OPERATION: Postaccelerator tunnel

21MeV/u



Residual field:
-high energy zone



copper structure
activation

-low energy zone





ion
implantation

In the high energy zone
continuous accessibility
after ~ week cooling time
or
occupancy factor of
minimum 570 hours/year
 $\Rightarrow 20 \text{ mSv y}^{-1}$



Maintenance operations
to be planed

150MeV/u



Points -> contact

Lines -> 1m distance

Total
activity

$H^*(10)$

HIAT'09, 8-12.06.2009-Venezia

Impact of radioactive releases: Source term

POSTACCELERATOR

Specific activity [Bq cm⁻³] in first 100 cm of soil/groundwater surrounding the concrete wall after 40 y of continuous irradiation

Isotope	T _{1/2}	Soil	Groundwater
³ H	12.33y	3.149*10 ⁻⁵	3.299*10 ⁻⁶
⁷ Be	53.12d	3.662*10 ⁻⁶	3.662*10 ⁻⁷
²² Na	2.6y	7.782*10 ⁻⁶	7.784*10 ⁻⁷
²⁴ Na	14.96h	7.551*10 ⁻⁶	7.583*10 ⁻⁷
³² P	14.26d	1.047*10 ⁻⁸	9.584*10 ⁻⁹
³⁵ S	87.32d	2.262*10 ⁻²³	4.938*10 ⁻⁹
⁴⁵ Ca	162.61d	8.111*10 ⁻⁶	7.800*10 ⁻⁷
⁴⁶ Sc	83.79d	6.833*10 ⁻⁷	2.540*10 ⁻²¹
⁵⁴ Mn	312.3d	2.217*10 ⁻⁷	3.674*10 ⁻¹³
⁵⁵ Fe	2.73y	2.679*10 ⁻⁶	4.912*10 ⁻¹²
⁶⁵ Zn	244.26d	3.867*10 ⁻⁸	5.880*10 ⁻¹²

5.265*10⁴ Bq < 10¹² Bq --LIMIT*

1.301*10⁴ Bq < 10⁵ Bq --LIMIT*

Transport of radioactive species into the ground does not represent a hazard for the population

**Real evaluation to be done after
the site will be chosen**



*IAEA TECDOC-1000, 1998,
Clearance of materials resulting from the use of
radionuclides in medicine, industry and research.

Impact of radioactive releases: waste disposal

Disposal of liquid Hg (FZJ)

A schematic layout for liquid Hg-target disposal strategy

Chemical stabilization of Hg as an inorganic compound, e.g. HgS , HgSe , HgO , Hg_2Cl_2 , HgCl_2



Extrapolation from laboratory scale to “industrial” scale still to be done!

Impact of radioactive releases: Dispersion of the radioactivity

NIPNE

Combination of knowledge on Accelerator & Research Reactor based nuclear installations

→ creation of dedicated toolkit for EURISOL DS

→ Methodology **validated, recommended & accepted** by safety authorities

→ **Tools, data & knowledge** to be used in

Environmental and health Impact Assessment


Toolkit operational both for normal operation and accidental situations!

Further steps:

- *Derived Intervention Levels (DIL)*
- *Exposure from underground water contamination*
- *Development of a resident GIS platform*
- *Cadastral Impact Analysis (GIS based)*
- ...

Site dependent analysis to be performed!

HIAT'09, 8-12.06.2009-Ven



The Map Manager



Summary

- ❑ Safety integration from the start hints innovative and flexible solutions in matters of safety
- ❑ EURISOL has similarities with high-power spallation n-sources & small research reactors


Very specific features:

- ✓ Use of pyrophoric actinide carbide targets;
- ✓ Presence of alpha-emitters;
- ✓ Distribution over extended buildings of intense RIBs and sources of all chemical nature

Dedicated technical standards to be applied under utmost reliable safety rules and procedures.

Back-up

CONVERTER: Parameters / Model



Target positions:

$z = 0$	T#5	T#1	T#3
$z = 15$	T#6	T#2	T#4
$x \Rightarrow$	-15	0	15
$y \Rightarrow$	-12.9	10	-12.9

❑ Geometry :

- ✓ Last design variant (L. Tecchio): 30kW load heat
- ✓ Volume = 181cm^3 ($R_{\text{ext}}=1.75\text{cm}$, $R_{\text{int}}=0.4\text{cm}$, $H=20\text{cm}$)

❑ Material:

- ✓ Targets: graphite + U, density= 1.88 g cm^{-3} , (mass U=15g | mase rate: $U/C=1/20$, MKLN)

✓ Moderator: H_2O , Fe (^{232}Th)

✓ Reflector: BeO , Fe (^{232}Th)

❑ Physics parameters:


✓ Source: α , $E=1\text{GeV}$, $C_{\text{area}} (\sigma = 1.5\text{cm})$

✓ Model: (

✓ $T=239\text{K}$


Results normalised at 1mA

CONVERTER: Results | Neutron flux



Configuration	Average $z=0\text{cm}$	Average $z=15\text{cm}$
^{235}U	5.1380E+13	5.6604E+13
20% ^{235}U	5.0084E+13	5.5219E+13
3% ^{235}U	4.9764E+13	5.4867E+13
U_{nat}	4.9707E+13	5.4811E+13
U_{dep}	4.9700E+13	5.4794E+13
^{232}Th	5.2496E+13	5.8150E+13


Neutron flux ($\text{n cm}^{-2} \text{s}^{-1}$)



Neutron Flux – distribution over the targets

Neutron Flux – energy distribution (T#1)

Converter: Results | Fission rates




Fission Rates – distribution over the targets

Configuration	$^{235}\text{U}^*$ (fiss/s)	^{238}U (fiss/s)	Total (fiss/s)	^{235}U [%]
^{235}U	5.7689E+14		5.7689E+14	100
20% ^{235}U	1.3823E+14	1.2021E+12	1.3943E+14	99.14
3% ^{235}U	2.1712E+13	1.3931E+12	2.3106E+13	93.97
U_{nat}	5.2449E+12	1.4172E+12	6.6621E+12	78.73
U_{dep}	1.4591E+12	1.4223E+12	2.8814E+12	50.64
^{232}Th	5.2366E+11		5.2366E+11	


* ^{232}Th for Th case

Fission Rates – total



Fission Rates –energy distribution (T#1)

COMPARISON: Direct vs Converter methods | Flux & Fission rates




Neutron flux: fission | spallation

Neutrons vs 1GeV protons

C(^{235}U) vs D(UC₃*)

* Direct target:
R=1.8cm, L=40cm




Neutron fission rate: fission | spallation

Configuration	$\Phi_{\text{avg}}(\text{n cm}^{-2} \text{s}^{-1})$ z=0cm	$\Phi_{\text{avg}}(\text{n cm}^{-2} \text{s}^{-1})$ z=15cm	Φ_{total} ($\text{n cm}^{-2} \text{s}^{-1}$)
Converter (^{235}U)	5.1380E+13	5.6604E+13	
Direct (UC ₃)			2.473E+13


Configuration	^{235}U (fiss/s)	^{238}U (fiss/s)	Total (fiss/s)
Converter (^{235}U)	5.7689E+14		5.7689E+14
Direct (UC ₃)	1.591E+11	4.0415E+13	4.0574E+13

COMPARISON: Direct vs Converter methods | Yields


Neutrons vs 1GeV protons




Yields – Sn: fission | spallation



Yields – Xe: fission | spallation



Yields – Ga: fission | spallation



Yields – Kr: fission | spallation

OPERATION:Containment | Risk register

Main risks for the Fission target






Major Risks:

- breaking of target container
- target firing

Consequences:

Dissemination of radioactivity in the environment

10^{15} fission fragments/sec per target
($\sim 5 \times 10^4$ Ci)



Luigi Tecchio – Task 4


OPERATION: containment of volatile radioactivity

Capability of Cryotrap (LMU)

3 cryotrap prototypes tested: retention capability (vs. pressure behind cryotrap)

‘carry over’: fraction of leaking gas load transported across cryotrap

2 trap types operated at different temperatures:



Cryotrap works within (simulated) expectations → 99.98% of volatile radioactivity can be localized!