

Redundant Windows servers running in hot standby mode

- Based on the WinCC Open Architecture software package
- Uses Joint COntrols Project (JCOP) and CMS frameworks
- 3-role access control (MONITOR / OPERATOR / EXPERT)



Applications archive / retrieve data from central databases

Alerts and protective automatic actions at all system levels



3 servers @ CMS data center ★1 Replacement of the chain CAN-USB-Ethernet by CAN-Ethernet ongoing $\star 2$ Implementation ongoing

24/7 On-call Services

- Two levels: Operator / Expert (also responsible for the safety system hardware)
- Contributes to the maximum availability of the detector
- Log of failures used for further system improvements and corrections



Remote reset of CAEN mainframes

DCS Name	Network Name	IP Address	Location	ECAL Partition	Clear Alarms	CPU Reset	Full Reset
ES_HV	ESHV01	10.176.62.22	S2G05	ES+ HV	Clear Alarms	CPU Reset	Full Reset
ES_HV2	ESHV02	10.176.62.24	S2G05	ES- HV	Clear Alarms	CPU Reset	Full Reset
ES_LV	ESBV01	10.176.64.13	S4F03	ES+LV, ES-LV	Clear Alarms	CPU Reset	Full Reset
cmsechv01	ECALHV11	10.176.3.10	S2B06	EB+1, EB+2	Clear Alarms	CPU Reset	Full Reset
cmsechv02	ECALHV12	10.176.62.109	S2B06	EB+3, EB+4	Clear Alarms	CPU Reset	Full Reset
cmsechv03	ECALHV13	10.176.62.111	S2B06	EB+5, EB+6	Clear Alarms	CPU Reset	Full Reset
cmsechvO4	ECALHV14	10.176.3.62	S2B07	EB+7, EB+8	Clear Alarms	CPU Reset	Full Reset
cmsechv05	ECALHV15	10.176.62.107	S2B07	EB+9, EB+10	Clear Alarms	CPU Reset	Full Reset
cmsechv06	ECALHV16	10.176.62.108	S2B07	EB+11, EB+12	Clear Alarms	CPU Reset	Full Reset
cmsechv07	ECALHV17	10.176.3.61	S2B08	EB+13, EB+14	Clear Alarms	CPU Reset	Full Reset
cmsechv08	ECALHV18	10.176.62.106	S2B08	EB+15, EB+16	Clear Alarms	CPU Reset	Full Reset
cmsechv09	ECALHV19	10.176.62.105	S2B08	EB+17, EB+18	Clear Alarms	CPU Reset	Full Reset
cmsechv10	ECALHV01	10.176.3.90	S2G06	EB-1, EB-2	Clear Alarms	CPU Reset	Full Reset
cmsechv11	ECALHV02	10.176.62.116	S2G06	EB-3, EB-4	Clear Alarms	CPU Reset	Full Reset
cmsechv12	ECALHV03	10.176.62.115	S2G06	EB-5, EB-6	Clear Alarms	CPU Reset	Full Reset
cmsechv13	ECALHV04	10.176.3.78	S2G07	EB-7, EB-8	Clear Alarms	CPU Reset	Full Reset
cmsechv14	ECALHV05	10.176.62.114	S2G07	EB-9, EB-10	Clear Alarms	CPU Reset	Full Reset
cmsechv15	ECALHV06	10.176.62.113	S2G07	EB-11, EB-12	Clear Alarms	CPU Reset	Full Reset
cmsechv16	ECALHV07	10.176.3.88	S2G08	EB-13, EB-14	Clear Alarms	CPU Reset	Full Reset
cmsechv17	ECALHV08	10.176.62.110	S2G08	EB-15, EB-16	Clear Alarms	CPU Reset	Full Reset
cmsechv18	ECALHV09	10.176.62.112	S2G08	EB-17, EB-18	Clear Alarms	CPU Reset	Full Reset
crateEM	EEHV03	10.176.62.28	S2G09	EE-	Clear Alarms	CPU Reset	Full Reset
crateEP	EEHV02	10.176.62.27	S2B09	EE+	Clear Alarms	CPU Reset	Full Reset

WIENER PFC monitoring

Readout of internal parameters of 136 Power Factor Correctors (PFC) via RS-232





- Arduino Ethernet with Modbus-TCP implementation
- 14 ports per unit, providing TTL output signals
- Heartbeat to ensure the unit availability
- Adjustable pulse length for available reset modes
- ✓ Easy integration with the detector control system
- ✓ Reduction of intervention time from >30min to <10min</p>
- ✓ Proven effectiveness in production environment

Improved PTM ELMB power distribution

Precision Temperature Monitoring (PTM) of the EB/EE crystals region and cooling



- ELMB-based readout of 516 NTC thermistors Original ELMB powering scheme: Single set of 3x 12V power supplies for all ELMBs
- * No easy way to disconnect an individual power line
- Single failure could degrade the complete system
 - Improved power distribution:



- Custom electronics features:
 - Arduino Yún with Modbus-TCP implementation
- 4x dual-channel 16-port MUX for serial line switching
- 9V and 5V supplies for the PFCs isolated serial circuit
- Easy integration with the detector control system

ES BV monitoring



Environment temperature sensors

Water leak sensors

- Largest ELMB-based system in the CMS ECAL (80 ELMBs)
- Monitors currents of 2216 individual bias voltage lines
- Readout of currents based on simple resistor networks
- ✓ Readout channels calibrated for precision better than 2%
- Important for identifying individual increases of currents
- Problem when working in a multiple ground configuration (🐳 investigation ongoing)

Barrel and Endcaps



- ✓ Two sets of 3x 12V power supplies, one for each detector half
- Terminal blocks with switches and fuses per power line
- ✓ Failures can be easily isolated at the CMS service cavern level

EB / EE humidity monitoring

	cupit .	Supervised in the local division of the loca	_	
EBP_01 27.7	28.6 30.6 33.1	EBM_01 36.4	36.6 33.0	25.7
EBP_02 33.2	34.8 36.0 36.9	EBM_02 32.2	32.1 29.7	22.1
EBP_03 33.8	35.6 37.7 36.5	EBM_03 33.4	27.8 22.8	10.9
EBP_04 38.5	43.1 44.4 40.8	EBM_04 44.2	42.1 36.5	23.9
EBP_05 40.8	46.2 46.1 45.4	EBM_05 45.7	42.4 32.1	15.3
EBP_06 35.1	39.6 42.0 44.9	EBM_06 42.9	43.1 33.8	15.6
EBP_07 36.0	38.4 40.1 41.5	EBM_07 37.9	36.3 31.1	15.5
EBP_08 34.6	37.6 40.0 40.8	EBM_08 39.1	35.2 29.1	14.7
EBP_09 35.7	33.8 37.3 39.6	EBM_09 41.3	37.8 32.1	22.4
EBP_10 10.1	12.9 20.8 28.2	EBM_10 39.4	36.1 28.4	19.0
EBP_11 26.7	28.3 31.6 32.9	EBM_11 37.3	35.3 29.7	21.8
EBP_12 11.4	15.6 22.8 28.0	EBM_12 32.2	28.7 25.4	14.6
EBP_13 22.7	27.0 27.3 26.3	EBM_13 22.0	21.1 18.5	12.7
EBP_14 10.0	13.3 12.4 11.3	EBM_14 11.3	14.0 18.4	13.4
EBP_15 9.0	10.3 12.1 14.0	EBM_15 11.6	15.1 20.8	15.0
EBP_16 8.3	8.9 11.4 20.4	EBM_16 24.3	25.7 25.6	19.9
EBP_17 9.9	13.1 16.5 22.4	EBM_17 32,6	33.5 32.3	26.2
EEP_F 56.4 EEP_N 55.6	57.6 59.0 56.0 55.1 53.7 55.7	EEM_F 53.9 EEM_N 54.5	54.6 54.9 56.4 57.2	53.3
✓ Module_1 45.7	9/30/2013 4:14:56 PM.946	Environment	/2013 4:14:56 PM.946	8
Module_3 32.1	9/30/2013 4:14:56 PM.946	Module_4 15.3 9/30	/2013 4:14:56 PM.946	œ
8				

- Custom electronics for the readout of 192 RH probes inside EB/EE
- Over one year of evaluation to operate probes out of specifications
- Very low frequency excitation to minimize cabling capacitance effect
- Commercial Modbus RTU-Ethernet adapters used
- Precise calibration at the CMS ECAL DCS laboratory facilities
- ✓ Readout range extended from 60-80% to 10-80% RH
- Expected performance fully demonstrated in production environment



Barrel/Endcaps



- Preventive maintenance performed regularly
- Protection to prevent users from setting unsafe thresholds
- Annual interlock tests for complete system verification
- ✓ CPUs replaced by newer models to ensure support until 2022
- Software mechanism for recovering communication to readout units

1) ETH Zurich, Switzerland 2) University of Belgrade, Serbia 3) University of Wisconsin, USA

Acknowledgements

Swiss National Science Foundation, Switzerland Ministry of Education, Science and Technological Development, Serbia