

Recent Progress in X-ray Emittance Diagnostics at SPring-8

S. Takano, M. Masaki, and H. Sumitomo *

JASRI/SPring-8, Hyogo, Japan

*SES, Hyogo, Japan **

Outline

Introduction

X-ray Pinhole Camera

X-ray Fresnel Diffractometry Monitor (XFD)

Conclusions

Introduction

Light Source Facilities are Competing to
Achieve Lower Emittance and Emittance Coupling Ratio for Higher Brilliance.

Serious and Elaborate Efforts are being Paid for
Upgrade Plans of Existing Rings or New Plans of Low Emittance Rings.

X-ray Synchrotron Radiation (SR) is
Key Diagnostic Probe for Non-Destructive Beam Emittance Measurement.

Both Direct Imaging and Interferometric Technique
can Resolve the Micrometer-order Transverse Beam Size.

Emittance is Obtained from the Measured Size
with Other Knowledge (Betatron and Dispersion Functions, Energy Spread).

Introduction

Two Alternative Targets of X-ray Emittance Diagnostics at Light Source Rings

Dipole Magnet Source and Insertion Device Source (Undulator)

It Seems from the View Point of Machine Operation that
Emittance Diagnostics of Dipole Source is Necessary and Sufficient
for Tuning the Beam of the Accelerator

Nonetheless,

Diagnostics of Undulator Source Emittance Cannot be Avoided
Because the Undulator is Just the Source of Light Delivered to Experimental Users




Two X-ray Instruments for Emittance Diagnostics Recently Implemented at SPring-8

Dipole Source: X-ray pinhole camera

Undulator source: X-ray Fresnel Diffractometry monitor (XFD)

X-ray Pinhole Camera @ SPring-8

Layout






X-ray Pinhole Camera @ SPring-8

Source: Dipole (29B2)

X-ray Window @ 6.2 m


$B = 0.5 \text{ T}$ $E_c = 21.1 \text{ keV}$




X-ray Pinhole Camera @ SPring-8

Pinhole Assembly @ 11.4 m



Aperture: $20\text{ }\mu\text{m} \times 20\text{ }\mu\text{m}$



Y slit
Tungsten 3mm thick




X slit
Tungsten 3mm thick



X-ray Pinhole Camera @ SPring-8

Scintillator & Camera Assembly @ 34.3m



Mirror

Scintillator


CdWO_4 (CWO)
0.5mm thick

Lens

object-space
telecentric
x2 magnification
W. D. = 111 mm



CCD Camera (Basler piA2400-17gm)
GigE interface
2448 x 2050 pixels
3.45 μm x 3.45 μm pixel size

manual XZ stage




X-ray Pinhole Camera @ SPring-8

Resolution of Pinhole (PSF calculation based on Wave Optics)







Pinhole Resolution (rms)

$$\sigma_{diff} = 6.9 \mu\text{m} \text{ @ } 42 \text{ keV}$$



X-ray Pinhole Camera @ SPring-8

Scintillator & Camera Assembly Resolution Calibration



sharpness of edge of W bar
placed in front of scintillator
measured

Resolution (rms) of
Scintillator & Camera Assembly

$$\sigma_{CAM} = 2.2 \mu\text{m}$$

X-ray Pinhole Camera @ SPring-8



Total Spatial Resolution σ_{XPC} (rms)

$$\sigma_{XPC} = \sqrt{\sigma_{diff}^2 + \sigma_{CAM}^2} = 7.2 \mu\text{m}$$

Pinhole $\sigma_{diff} = 6.9 \mu\text{m}$
Scintillator & Camera $\sigma_{CAM} = 2.2 \mu\text{m}$

Scale of Camera Pixel to Beam Coordinate



measured by introducing vertical bump orbits



consistent with
designed value $0.8625 \mu\text{m/pixel}$

X-ray Pinhole Camera @ SPring-8

Example of data $I = 100$ mA, exposure time 1 ms




Projected profiles
(horizontal and vertical)
consistent with
Gaussian profiles

Projected Beam Size
 $\sigma_x = 96.0 \mu\text{m}$
 $\sigma_y = 16.6 \mu\text{m}$
(resolution subtracted)

X-ray Pinhole Camera @ SPring-8

Control Room Display



Live Beam Image View
~ 15 fps

Parameters of Beam Profile
beam size σ_x and σ_y
beam tilt angle θ
Continuously Logged
to SPring-8 Control Database


By Periodical Image Analysis
(1s cycle time)

2D Gaussian Profile is
Fitted to Beam Image Data

$\epsilon_y = 7.5 \text{ pm.rad}$
(coupling 0.3%)

X-ray Pinhole Camera @ SPring-8

Control Room Display



Live Beam Image View
~ 15 fps

Parameters of Beam Profile
beam size σ_x and σ_y
beam tilt angle θ
Continuously Logged
to SPring-8 Control Database

By Periodical Image Analysis
(1s cycle time)

2D Gaussian Profile is
Fitted to Beam Image Data


$\epsilon_y = 7.5 \text{ pm.rad}$
(coupling 0.3%)

X-ray Pinhole Camera @ SPring-8

Diagnostics for User Operation: Betatron Coupling induced by ID20


ID error fields excite betatron coupling in user operation.

Betatron coupling is corrected by tuning skew Q parameters.




X-ray Pinhole Camera @ SPring-8

Diagnostics for Machine Tuning: Betatron Coupling induced by ID10



Search for
Correcting skew Q parameters



* radiation induced-demagnetization of ID10 suspected, and B field readjusted in March 2015

X-ray Pinhole Camera @ SPring-8

Preliminary Plan for SPring-8 Upgrade (SPring-8-II)

Source: Dipole Magnet


Layout (distance from source)

Pinhole: 6.5m, Scintillator: 32m



Pinhole

Magnification : x 3.9

Size: 20 μm x 20 μm



Point Spread Function (Wave Optics Calculation)



Pinhole Resolution (rms) better than 5 μm
feasible for 40 – 50 keV X-rays

Resolution of Present Scintillator Assembly
scales to 1.1 μm

X-ray Pinhole Camera @ SPring-8

Summary

Specifications of the SPring-8 X-ray Pinhole Camera		
Light Source	Bending Magnet (29B2)	
Pinhole	Distance from Source (m)	11.4
	Aperture Size (μm)	20 x 20
Scintillator	Distance from Source (m)	34.3
	Material	CdWO_4
Camera	Number of Pixels	2448 x 2050
	Pixel Size (μm)	3.45 x 3.45
Magnification Factor	x 4 (Pinhole: x 2, Lens: x 2)	
Resolution (rms) (μm)	7.2 (Pinhole: 6.9, Scintillator & Camera: 2.2)	

Live Beam Image View @ Control Room ~ 15 fps

Parameters of Beam Profile Continuously Logged to SPring-8 Control DB

Indispensable for Beam Tuning and User Operation


Resolution (rms) Better than 5 μm Feasible for Upgrade Plan of SPring-8

X-ray Fresnel Diffractometry Monitor (XFD)

Principle


M. Masaki et al., IBIC2014 TUCZB1 (2014).

M. Masaki et al., Phys. Rev. ST Accel. Beams 18, 042802 (2015).




Diffraction patterns depending on a width A of the slit

Fresnel Diffraction
wide slit ($A^2 > R\lambda$)




Double-Lobed
Fresnel Diffraction



optimum slit width
for the deepest dip

$$A \approx \sqrt{7\lambda \frac{LR}{L+R}}$$



Fraunhofer Diffraction
narrow slit ($A^2 \ll R\lambda$)



The depth of a median dip correlates with a light source size.

XFD @ SPring-8

Setup for Initial Experiments



optimum slit width A
for the deepest dip

$$A \approx \sqrt{7\lambda \frac{LR}{L+R}}$$

- P43 Screen
- lenses
- CCD camera
- min. exp. time: 1ms
- resolution σ_{res} : $6.8 \mu\text{m}$

XFD @ SPring-8

Initial Results



M. Masaki et al., IBIC2014 TUCZB1 (2014).

M. Masaki et al., Phys. Rev. ST Accel. Beams 18, 042802 (2015).

X-ray energy **7.2 keV**

slit width **$\Delta Y = 150 \mu\text{m}$**

Fitted function:
$$f(y) = C \int_{-\infty}^{\infty} \underbrace{I(y, y_e)}_{\text{PSF}} \exp \left[-\frac{(y_e - y_0)^2}{2(\underbrace{\sigma_{y,e}^2}_{\text{Source Size}} + \underbrace{\sigma_{res}^2}_{\text{Camera Resolution}})} \right] dy_e$$



Undulator source size smaller than $10 \mu\text{m}$ successfully resolved

XFD @ SPring-8


Recent Progress

New X-ray Imaging Setup




Imaging Resolution (rms) @ Source Point:


2.2 μm <- 6.8 μm (previous)



Increased Observing Energy: 16 keV



Result



exp. time
0.5 ms

source size
6.3 μm (rms)

$\epsilon_y = 7.9 \text{ pm.rad}$
(coupling 0.3%)

XFD

Summary

Diagnostic technique for light source rings
to measure small beam size at ID (undulator) source point

Able to resolve beam size smaller 5 μm

Requires only
slit, monochromator, and imaging device (X-ray camera)

Has potential universal availability to ID beamlines of the
diffraction limited storage rings (DLSRs)

Conclusions

SPring-8 X-ray Pinhole Camera

Resolution (rms) $\sim 7 \mu\text{m}$

Live Beam Image View @ Control Room $\sim 15 \text{ fps}$

Beam Parameters Logged to Control DB by Periodical (1s cycle) Image Analysis

Indispensable for Beam Tuning and User Operation of SPring-8

X-ray Fresnel Diffraction (XFD) Monitor

Diagnostic Technique for Light Source Rings
to Measure Small Beam Size at ID (Undulator) Source Point

Requires Only
Slit, Monochromator, and Imaging Device (X-ray Camera)

Able to Resolve Beam Size smaller $5 \mu\text{m}$

Acknowledgements

Many thanks to

colleagues of SPring-8/SACLA and SES

For their help in

vacuum, alignment, control and operation etc.

Thank you for your attention !