

# LONGITUDINAL BEAM PROFILE DIAGNOSTIC SYSTEM **AT BOOSTER OF ELECTRONS AND POSITRONS BEP**



M. Timoshenko<sup>\*</sup>, Yu. Zharinov, E. Perevedentsev, Yu. Rogovsky, D. Shwartz,

BINP SB RAS, Novosibirsk, Russia \* Email: tim94max@gmail.com

### **INTRODUCTION**

The longitudinal beam profile measurement system based on optical dissector was upgraded at booster synchrotron BEP during VEPP-2000 collider complex 2017/2018 data taking run. New RF cavity of 13-th harmonic was installed during the booster upgrade in 2013-2015 to increase top energy to 1 GeV. The complex work on synchrotron radiation output modernization was performed, and measurement system was commissioned. The system was tested and calibrated, the resolution was studied. The bunch length dependence was measured for different RF cavity voltages while beam current changes and compared with the potential well distortion model. Good agreement with theory proved system operability. In addition the results of bunch length current dependence obtained by dissector at VEPP-2000 collider were compared with streak-camera measurements being in a good agreement. The synchrotron tune dependence on RF cavity voltage was measured both at BEP and VEPP.

### **OPTICAL PATH MODERNIZATION AT THE BEP**

The task of modernization concludes in to save current beam transverse position monitor (CCD-camera) functional. For realization it and duplicating light of synchrotron radiation semitransparent mirror was setted in optical table tract (yellow part of table and mirrors at the **concept** figure was added in the modernization).



Parameter	Symbol	Value	Parameter	Symbol	Value
Circumference	П	2235 cm	Circumference	П	2439 cm
Revolution frequency	$f_0$	13.4145 MHz	<b>Revolution frequency</b>	$f_0$	12.2925 MHz
Momentum			Momentum		
compaction factor	$\alpha_p$	0.0576	compaction factor	$\alpha_p$	0.0359
Energy spread	$\frac{\hat{\sigma_E}}{E}$	$7.3 \cdot 10^{-4}$	Energy spread	$\frac{\sigma_E}{E}$	$7.1\cdot 10^{-4}$
Energy lose per turnover	$\mathbf{\bar{W}}$	69 keV	Energy lose per turnover	$\mathbf{\bar{W}}$	63.2 keV
Harmonic of cavity	h	13	Harmonic of cavity	h	14
Bending radius	$r_0$	128 cm	Bending radius	$r_0$	140 cm
Maximum cavity voltage	$U_{max}$	110 kV	Maximum cavity voltage	$U_{max}$	100 kV
Synchrotron frequency			Synchrotron frequency		
(normalized at $f_0$ )	$\mathcal{V}_{S}$	0.0032	(normalized at $f_0$ )	$\nu_s$	0.0025

After preliminary alignment the optical table with both devices was installed to BEP synchrotron radiation output and the final tuning was completed with very low intensity beam (around 100 mkA) in the BEP. —





Developed application for measurements where examples of longitudinal bunch profile in the BEP and history of bunch length measurements are showed.



### MEASUREMENTS

Normalized synchrotron frequency and bunch length at "null" bunch intensity versus RF cavity voltage at the **BEP**.





### DISSECTOR

Dissector is a optical stroboscopic device. One of the way of applying it is registration longitudinal distribution of beam charge in a circular accelerators where the beam motion is strictly periodical. For dissector installed at the BEP resolution is 26 ps (or 0.8 cm in spacial dimension).



### CONCLUSION

In work season 2017-2018 the longitudinal beam profile diagnostic get comprehensive development. Dissector has been installed at the BEP. Two more identical dissectors has been set to VEPP-2000 collider. All dissectors has been calibrated. For using them the special software has been developed. After that these systems has been commissioned by operators of complex VEPP-2000. Also the streak-camera has been installed at VEPP-2000 collider. Joint measurements of bunch length by dissector and streak-camera at the VEPP-2000 collider and comprehensive measurements of bunch length in the BEP in model of potential well distortion have been done.



Calibration of dissector is implemented by calibration source of permanent light. Scaling factor and estimation of resolution can be found.

Final formula of input pulse duration is:  $\Delta l =$ 

Dissector device components: 1 - dissector LI-602, 2 - adapter of dissector, 3 - shielding shell, 4 - slit for alignment final short-focus lens, 5 - oscillatory RF circuit.

 Table 2: LI-602 parameters)

Parameter	Value
Voltage slit — photo-cathode	10 kV
Voltage slit — focusing electrode	$10 \pm 1 \text{ kV}$
Max. voltage at deflection plates	2.5 kV
Max. spectrum sensitivity	440 – 470 nm
Multiplier voltage	-1.52.0 kV
Slit width	50 mkm



## REFERENCES

[1] D. Shwartz, D. Berkaev et al., "Recent beam-beam effects and luminocity at VEPP-2000",

in Proc. 5th International Particle Accelerator Conference. (IPAC'14), Dresden, Germany, June 2014, pp. 924-927. doi:10.18429/JACoW-IPAC2014-TUOBA03

[2] D. Shwartz, D. Berkaev et al., "Booster of electron positron (BEP) upgrade to 1 GeV",

in Proc. 5th International Particle Accelerator Conference. (IPAC'14), Dresden, Germany, June 2014, pp. 102-104. doi:10.18429/JACoW-IPAC2014-MOPRO018

[3] Yu. Maltseva, A. Andrianov et al., "VEPP-5 injection complex: new possibilities for BINP electron-positron colliders", in Proc. 9th International Particle Accelerator Conference. (IPAC'18), Vancouver, BC, Canada, Apr. 2018, pp. 371-373. doi:10.18429/JACoW-IPAC2018-MOPMK011

[4] E. I. Zinin and O. I. Meshkov, "Optical dissector for longitudinal beam profile measurement",

Journal of Instrumentation, vol. 10, p. 10024, Oct. 2015, doi:10.1088/1748-0221/10/10/P10024

[5] O. I. Meshkov, E. I. Zinin et al., "Development, calibration and application of new-generation dissector with picosecond temporal resolution",

in Proc. 7th International Particle Accelerator Conference. (IPAC'16), Busan, Korea, May 2016, paper MOPMR013, pp. 251-254.

[6] B. Zotter, "The effective coupling impedance for bunched beam instabilities",

CERN, Geneva, Switzerland, Rep. CERN-ISR-TH-78-16, Jul. 1978. [7] A. Senchenko, D. Berkaev et al., "VEPP-2000 collider control system",

in Proc. 9th International Workshop on Personal Computers and Particle Accelerator Controls. (PCaPAC'12), Kolkata, India, 2012, Dec. 2012, paper FRCB04, pp. 263-274.

[8] A. Chao, M. Tigner, Handbook of accelerator physics and engineering. 2nd Printing. Singapore: Mainland Press, 1999.

[9] V. Borin, "Research of energy spread and beam profile in BINP circular accelerators". Master's degree dissertation, 1999, BINP, unpublished.